2025 PIPELINE EMERGENCY QUICK REFERENCE GUIDE - MLGPA

EMERGENCY CONTACT LIST

Company Name	Emergency Number
Bridger Pipeline LLC	1-866-305-3741
Calumet Montana Refining, LLC	
Cenex Pipeline, LLC	1-800-421-4122
Colorado Interstate Gas Company	1-877-712-2288
Denbury Inc. (ExxonMobil)	1-888-651-7647
Energy West	1-800-570-5688
Energy West (Cascade county)	1-406-791-7500
Energy West (Gallatin county)	1-406-646-4437
Energy West (Glacier county)	
Express Pipeline LLC (Enbridge)	1-800-858-5253
Front Range Pipeline, LLC	1-800-421-4122
Havre Pipeline Company	1-888-467-2669
Kinder Morgan Double H	1-877-977-2078
Montana-Dakota Utilities Company	1-800-638-3278
MPLX	1-866-283-7676
NorthWestern Energy	1-888-467-2669
Par Montana LLC / Par Rocky Mountain Midstream LLC	1-888-550-7766
Phillips 66 Pipelines LLC	1-877-267-2290
Plains Pipeline, L.P.	1-800-708-5071
Silver Creek Midstream	1-866-628-1693
TC Energy Natural Gas	1-800-447-8066
WBI Energy Transmission	1-888-859-7291



To learn more about your local pipeline operators, please visit <u>mlgpa.pipelineawareness.org</u>

Note: The above numbers are for emergency situations. Additional pipeline operators/companies may exist in your area. Visit the National Pipeline Mapping System at www.npms.phmsa.dot.gov for transmission companies not listed above.

One-Call System Phone Number

2025 PIPELINE EMERGENCY QUICK REFERENCE GUIDE - MLGPA

INCIDENT RESPONSE

┙	■ Always approach from upwind/	park vehicle a safe distance
	away/if vehicle stalls – DO NO	T attempt to restart

- ☐ Gather information/establish incident command/identify command structure
- ☐ Initiate communications with pipeline/gas company representative ASAP
- Control/deny entry: vehicle, boat, train, aircraft, foot traffic, media – refer all media questions to pipeline/gas representatives

RISK CONSIDERATIONS

	Type/volume/	/pressure/lo	cation/geo	graphy of	product
_	. , , , , , , , , , , , , , , , , , , ,	p. 0 0 0 0 0, . 0		g. s.p,	p

- ☐ Environmental factors wind, fog, temperature, humidity
- ☐ Sight, sound, smell indicators vary depending on product
- ☐ Black, dark brown or clear liquids/dirt blowing into air/ peculiar odors/dead insects around gas line/dead vegetation
- ☐ Rainbow sheen on the water/mud or water bubbling up/ frozen area on ground/frozen area around gas meter
- Other utility emergencies

PIPELINE MARKERS

The U.S. Department of Transportation (DOT) requires the use of signs to indicate the location of underground pipelines. Markers like these are located on road, railroad, and navigable waterway crossings. Markers are also posted along the pipeline right-of-way. Markers may not be located directly over the pipeline it marks.

The markers display:

- The product transported
- ☐ The name of the pipeline operator
- ☐ The operator's emergency number





PRODUCT HAZARDS AND CHARACTERISTICS

Petroleum (flow rate can be hundreds of thousands of gallons per hour) TYPE 1

- Flammable range may be found anywhere within the hot zone
- ☐ H2S can be a by-product of crude oil

Type 1 Products	Flash Point	Ignition Temperature
Gasoline	- 45 °F	600 °F
Jet Fuel	100 °F	410 °F
Kerosene	120 °F	425 °F
Diesel Fuel	155 °F	varies
Crude Oil	25 °F	varies

Natural Gas (flow rate can be hundreds of thousands of cubic feet per hour) TYPE 2

- ☐ Flammable range may be found anywhere within the hot zone between 4% and 15%
- Rises and dissipates relatively quickly
- ☐ H2S can be a by-product of natural gas PPM = PARTS PER MILLION

• 0.02 PPM	Odor threshold
• 10.0 PPM	Eye irritation

 100 PPM Headache, dizziness, coughing,

vomiting

 200-300 PPM Respiratory inflammation within 1 hour

of exposure

• 500-700 PPM Loss of consciousness/possible death

in 30-60 min.

• 700-900 PPM Rapid loss of consciousness; death

possible

 Over 1000 PPM Unconsciousness in seconds; death in

minutes

Incomplete combustion of natural gas may release carbon monoxide

- Storage facilities may be present around populated areas/ can be depleted production facilities or underground caverns
- Gas travel may be outside the containment vessel along the natural space between the pipe and soil
- Lower/Upper Explosive Limit depends on characteristics of gas (SDS)

Propane, Butane and Other Similar Products - TYPE 3

(*e.g. Carbon Dioxide / Anhydrous Ammonia)

- ☐ Flammable range may be found anywhere within the hot zone
- ☐ Products cool rapidly to sub-zero temperatures once outside the containment vessel
- Vapor clouds may be white or clear

Type 3 Products Flash Point Ignition Temperature - 150 °F 920-1120 °F Propane Butane - 60 °F 725-850 °F - 51 °F 1204-1560 °F Anhydrous Ammonia

- * Caustic Can freeze/burn skin
- * Expands Rapidly
- * Liquid to a fog gas state!

